

**BUILDING DEPARTMENT**  
SUMPTER TOWNSHIP  
23480 SUMPTER RD.  
BELLEVILLE, MI 48111  
(734) 461-6201 EXT# 233

**CHECK LIST**

(Check before rough inspection)

**PLUMBING**

1. Install factory frost free sill cocks with built in vacuum breaker or add vacuum breaker to outside hose connection.
2. Install air chambers for plumbing fixtures.
3. Install pip hangers at required distances.
4. Install fire stop and nail plates for water and DWV piping.
5. TABLE P-605-12: FITTINGS FOR CHANGE IN DIRECTION  
No sanitary tees shall be used for vertical to horizontal or horizontal-to-horizontal connections for sanitary drainage systems.

**MECHANICAL**

1. Minimum 6" clearance to combustible material for single wall vent connectors for furnace and water heater.
2. No connections for gas piping inside furnace cabinet (unions, couplings, etc.)
3. Union, shut-off valve, and drip leg must be installed for water heater and furnace gas connection. Install shut off valves for all appliances.
4. Combustion air shall be provided for enclosed appliance rooms.
5. Maintain minimum clearance for exhauster terminations of high efficiency appliances from doors, windows and gas meter or regulator (LP & nat.) per code or manufacture instructions.
6. Flexible duct connectors shall be limited to 14' in length with minimum flame spread 25 or less – minimum smoke 50 or less and shall not be installed in concealed areas or penetrate a fire wall, floor or ceiling.